

- 1. INSTALLATION OF THE IRRIGATION "SUBTRACTION" METER SHALL BE DONE IN ACCORDANCE WITH ANY APPLICABLE UNIFORM PLUMBING CODES AND/OR CITY OF NAPA STANDARDS.
- THE PROPERTY OWNER SHALL PROVIDE THE DISTRICT WITH A DRAWING SHOWING THE LOCATION OF THE IRRIGATION "SUBTRACTION" METER.
- 3. THE PROPERTY OWNER SHALL PROVIDE THE DISTRICT WITH THE BRAND NAME, MODEL NUMBER AND SERIAL NUMBER OF THE IRRIGATION "SUBTRACTION" METER. THE METER SHALL BE A BADGER TYPE (OR EQUAL) METER WHICH READS IN THOUSANDS OF GALLONS. THE METER SHALL BE INSTALLED IN A CHRISTY B-16 (OR EQUAL) METER BOX.

## NAPA SANITATION DISTRICT



TYPICAL INSTALLATION IRRIGATION "SUBTRACTION"

METER

DATE:	MAY 2012
CHECKED BY:	MW
APPROVED BY:	TH
SCALE:	NONE

DRAWING NO.

**SS-17**