


NOTES

1. RECYCLED WATER IMPROVEMENTS SHALL CONFORM WITH RW-17
2. ANY EXISTING FILL LINES (POTABLE WATER/WELL WATER) SHALL BE REMOVED OR RE-CONSTRUCTED WITH AN AIR GAP EITHER TWICE THE SUPPLY PIPE DIAMETER OR A MINIMUM OF 12".
3. RECYCLED WATER FILL LINE MUST BE CONTINUOUSLY MONITORED DURING RESERVOIR FILLING.
4. RESERVOIR SHALL BE OUTFITTED WITH FILL MARKER VISIBLE FROM FLOW CONTROL VALVE.

NAPA SANITATION DISTRICT

	TITLE RECYCLED WATER RESERVOIR FILL REQUIREMENTS	DATE: JUN 2021	DRAWING NO. RW-14
		CHECKED BY: SK	
		APPROVED BY: AD	
		SCALE: NONE	